

DMR Copy of Record

Permit					
Permit #:	CO0032999	Permittee:	Littleton/Englewood Cities of	Facility:	LITTLETON/ENGLEWOOD, CITIES OF
Major:	Yes	Permittee Address:	2900 S Platte River Dr Englewood, CO 80110	Facility Location:	2900 SOUTH PLATTE RIVER DR ENGLEWOOD, CO 80110
Permitted Feature:	001 External Outfall	Discharge:	001-A Discharge to S Platte River <34 MGD		

Report Dates & Status					
Monitoring Period:	From 03/01/17 to 03/31/17	DMR Due Date:	04/28/17	Status:	NetDMR Validated

Considerations for Form Completion
 Oil and grease - see I.A.1, pg 2. If no chlorine was used, report "NCT" (no chlorine treatment). Antidegradation limits - see I.C.1, pg 19. Report influent samples on DMR marked 300I.

Principal Executive Officer					
First Name:		Title:		Telephone:	
Last Name:					

No Data Indicator (NODI)
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00010	Temperature, water deg. centigrade	1 - Effluent Gross	0	--	Sample						=	16.7		=	17.2	04 - deg C	99/99 - Continuous	RC - Recorder (auto)		
					Permit Req.															
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.1		=	7.3	12 - SU	05/WK - Five Per Week	GR - GRAB		
					Permit Req.						>=	6.5 MINIMUM		<=	9 MAXIMUM	12 - SU	05/WK - Five Per Week	GR - GRAB		
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	2		=	2	19 - mg/L	01/01 - Daily	CP - COMPOS		
					Permit Req.						<=	30 30DA AVG		<=	45 MX 7D AV	19 - mg/L	02/07 - Twice Every Week	CP - COMPOS		
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	3	--	Sample						=	2.3		=	4.3	19 - mg/L	01/01 - Daily	CP - COMPOS		
					Permit Req.						<=	7 30DA AVG		<=	16 DAILY MX	19 - mg/L	01/01 - Daily	CP - COMPOS		
					Value NODI															
00615	Nitrogen, nitrite total [as N]	1 - Effluent Gross	0	--	Sample									=	0.34	19 - mg/L	01/01 - Daily	CP - COMPOS		
					Permit Req.															
					Value NODI															
00620	Nitrogen, nitrate total [as N]	1 - Effluent Gross	0	--	Sample									=	15.8	19 - mg/L	01/01 - Daily	CP - COMPOS		
					Permit Req.															
					Value NODI															
00640	Nitrogen, inorganic total	1 - Effluent Gross	3	--	Sample		=	3478	26 - lb/d					=	20	19 - mg/L	01/01 - Daily	CP - COMPOS		
					Permit Req.		<=	6675 DAILY MX	26 - lb/d				<=	23.5 DAILY MX	19 - mg/L	01/01 - Daily	CP - COMPOS			
					Value NODI															
00718	Cyanide, weak acid, dissociable	1 - Effluent Gross	0	--	Sample									<=	6.2 DAILY MX	28 - ug/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.															
					Value NODI															
01046	Iron, dissolved [as Fe]	1 - Effluent Gross	0	--	Sample								=	113	28 - ug/L	01/07 - Weekly	CP - COMPOS			
					Permit Req.								<=	300 30DA AVG	28 - ug/L	01/07 - Weekly	CP - COMPOS			
					Value NODI															
01323	Selenium, potentially dissolved	1 - Effluent Gross	0	--	Sample								=	1.12	28 - ug/L	01/07 - Weekly	CP - COMPOS			
					Permit Req.								<=	4.6 30DA AVG	28 - ug/L	02/30 - Twice Per Month	CP - COMPOS			
					Value NODI															
													=	1.87	28 - ug/L	02/30 - Twice Per Month	CP - COMPOS			

